SCOPE OF WORK:

INTERIOR BUILD OUT / TENANT IMPROVEMENT

FINISH REQUIREMENTS

1. ALL NEW INTERIOR FINISHES TO COMPLY WITH NFPA 101-12.3.3 AND FBC 2020 CHAPTER 8.

2. WHERE INTERIOR FINISH MATERIALS ARE APPLIED ON WALLS, CEILINGS OR STRUCTURAL ELEMENTS REQUIRED TO HAVE A FIRE—RESISTANCE RATING OR TO BE OF NONCOMBUSTIBLE CONSTRUCTION, THEY SHALL COMPLY WITH THE PROVISIONS OF FBC 2017

3. INTERIOR WALL AND CEILING FINISHES REQUIREMENTS BY OCCUPANCY

- ALL EXTERIOR FRAMING WALLS TO BE FILLED W/ INSULATION FOAM (R 14.2).
- 1/2" DRYWALL ON 7/8 MTL. HIGH HAT ON FOIL INSULATION R 4.5.

INSULATION NOTE:

• MIN R30 BAT INSULATION TO BE PROVIDED ABOVE THE CEILING .

ACCESSIBILITY

- 1_ALL HANDICAPPED REQUIREMENT SHALL COMPLY WITH STANDARD ADA AND FLORIDA ACCESSIBILITY CODE
- 2-NOT USED
- 3-CHANGE OF ELEVATION NOT TO EXCEED 1/2" ON LEVEL AT ANY FLOOR LEVEL
- 4-ALL COMMON AREAS MUST BE HANDICAPPED ACCESSIBLE..

FRAMING AND BLOCKING NOTES


- STEEL STUDS SUPPORTING WALL HUNG PLUMBING FIXTURES SHALL BE DOUBLED OR NOT LESS THAN 20 GAUGE WITH A MINIMUM EFFECTIVE MOMENT OF INERTIA EQUAL TO 0.864 IN
- SUCH STUDS SHALL BE RIGIDLY CONNECTED TOP AND BOTTOM TO PREVENT SIGNIFICANT END ROTATION AND DISPLACEMENT.
- A HORIZONTAL MEMBER SECURELY FASTENED TO NOT LESS THAN TWO STUDS SHALL BE INSTALLED FOR THE ATTACHMENT OF EACH WALL HUNG PLUMBING FIXTURE.
- CONTRACTOR TO VERIFY ALL FIRE WALLS AND REPAIR AS NEEDED TO PROVIDE ONE-HOUR FIRE SEPARATION.


NOTE:


- USE WATER RESISTANCE DRY WALL IN ALL WET AREAS. (RESTROOMS, KITCHEN,....) .
- USE WATER RESISTANCE DRY WALL BEHIND WATER FOUNTAINS .

PROJECT DATA:

DESCRIPTION OF USE:	EXISTING RESTAURANT PRIVET DINING AREA IN SUITE 3 & SUPPLY STORAGE AREA IN SUITE 2.	
PROPOSE OCCUPANCY GROUP:	ASSEMBLY GROUP (A-2) .	
	(DINING HALL WTH OCCUPANCY LESS THAN 50)	
CODE NOTES		
CODE EDITION:	FLORIDA BUILDING CODE - BUILDING	2020
	FLORIDA BUILDING CODE - EXISTING BUILDING	2020
	FLORIDA FIRE PREVENTION CODE 6th EDITION.	
EXISTING BUILDING:		
EXISTING BUILDING:	EXISTING STRUCTURE	
	EXISTING STRUCTURE	
BUILDING NUMBER OF STORIES: OCCUPANCY	1	
BUILDING NUMBER OF STORIES:	1 PROPOSED ASSEMBLY GROUP (A-2).	
BUILDING NUMBER OF STORIES: OCCUPANCY	1	
BUILDING NUMBER OF STORIES: OCCUPANCY	1 PROPOSED ASSEMBLY GROUP (A-2). EXISTING (TYPE III)	
BUILDING NUMBER OF STORIES: OCCUPANCY TYPE OF CONSTRUCTION	1 PROPOSED ASSEMBLY GROUP (A-2). EXISTING (TYPE III) (NON SPRINKLERED)	







IG No: 22116 J Checked: SE Date:09/08/2022

ORANAD, INTERIOR R

PROJECT:

STREET. SUITE 2&3 ALE , FLORIDA 33308

Revisions:

ALL IE REPRE OF TH USE CONTROL OF SU USED FOR A WRITTE OVER RESPOND THE A DIMEN DIMEN DIMEN

oup Inter

SHEET

OF SHEETS

SCALE 1'=1/4"